



Certificate G59/2

Engineering Recommendation

Manufacturer:	<i>Jiangsu Eversolar New Energy CO., LTD.</i>
Address:	<i>Building 9 No.198 Xiangyang Road,Suzhou</i>
Postal code,place:	<i>215011</i>
Country:	<i>China</i>
Test house details:	<i>Jiangsu Eversolar New Energy CO., LTD. R&D Department, Suzhou</i>
Type reference:	<i>Eversolar string Inverter Eversol-TLC17K-GB Eversol-TLC15K-GB Eversol-TLC12K-GB Eversol-TLC10K-GB</i>
Nominal AC power:	<i>17000W/15000W/12000W/10000W</i>

The results of the G59/2 tests are summarized in this certificate. Eversolar declares hereby that all units shipped to the UK are within the specifications and parameters set by the G59/2 engineering recommendation. These settings cannot be changed by an installer user or by any person other than Eversolar. Complete documentation on test details are available at Eversolar on demand.

Test details

Power quality

Harmonic current emissions as per BS EN 61000-3-11 A

Voltage fluctuations and flicker as per BS EN 61000-3-12 A

Power factor

Under / Over frequency switch off

Under / Over voltage switch off

Loss of mains test

Jiangsu Eversolar New Energy CO., LTD.

Suzhou,01-07-2011

A handwritten signature in black ink, consisting of the Chinese characters "金海燕" (Jin Haiyan).

Director of R&D

Certificate No. CN/TLC17K-GB20110701G59/2